

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY (WATER ANALYSIS REPORT)

REF. NO: -1344


REF.DATE:-22 /05/26

Sample provided by :-Mayor World School,Urban Estate,Phase 1,Jalandhar

SR.NO	TEST	REQUIRED LIMIT IS10500	SAMPLE
1	COLOUR	5 Hazen	Colorless
2	ODOUR	Unobjectionable	Normal
3	TASTE	Agreeable	normal
4	PH	6.5 – 8.5	6.8
5	DISSOLVED SOLIDS (TDS)	500 ppm	140
6	TOTAL HARDNESS (as CaCO ₃)	300 mg/l	116
7	ALKALINITY	200 mg/l	90
8	CALCIUM (as Ca++)	75 mg/l	12.2
9	IRON	0.3 mg/l	0.1
10	CHLORIDE	250 mg/l	26
11	SULPHATES	150 mg/l	nil
12	NITRATES	4.5 mg/l	nil
13	FLOURIDE	1.0 mg/l	o.1
14	RESIDUAL CHLORINE	0.2 mg/l	nil
15	TOTAL COLLIFORM COUNT (by MPN method per 100ml)	NIL	nil

REMARKS :-

provided water sample found satisfactory as per applied tests



DATE: 25 /05/26

Deepest Kumar
Analyst

ANALYST
MUNICIPAL CORPORATION JALANDHAR